

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WEST DAVIESS COUNTY)	
WATER DISTRICT FOR A CERTIFICATE OF)	CASE NO. 94-340
PUBLIC CONVENIENCE AND NECESSITY TO)	
CONSTRUCT WATER LINE EXTENSIONS)	

O R D E R

IT IS ORDERED that West Daviess County Water District ("West Daviess") shall file an original and 10 copies (two copies of engineering-related materials) of the following information with the Commission, with a copy to all parties of record within 21 days from the date of this Order. West Daviess shall furnish with each response the name of the witness who will be available at the public hearing, if one is held, for responding to questions concerning each item of information requested.

1. Provide a copy of the Bid Tabulation when the bids are received.

2. Provide a copy of the final summation of the total cost of construction and funding arrangements referred to as the Final Engineering Report.

3. In its application West Daviess proposes to install six and relocate four fire hydrants as part of this project. 807 KAR 5:066, Section 10(2)(b), states in part "[f]ire hydrants may be installed by a utility only if: a. A professional engineer with a Kentucky registration has certified that the system can provide a minimum fire flow of 250 gallons per minute; and b. The system

supporting this flow has the capability of providing this flow for a period of not less than two (2) hours plus consumption at the maximum daily rate."

Provide documentation that the system meets the requirements of 807 KAR 5:066, Section 10(2)(b).

Done at Frankfort, Kentucky, this 20th day of October, 1994.

PUBLIC SERVICE COMMISSION


For the Commission

ATTEST:


Executive Director